## Circuit breaker 3-pole 250A, system/cable protection, withdrawable unit



Part no. NZMS2-A250-SVE 113291

General specifications	
Product name	Eaton Moeller series NZM molded case circuit breaker thermo-magnetic
Part no.	NZMS2-A250-SVE
EAN	4015081128266
Product Length/Depth	180 millimetre
Product height	245 millimetre
Product width	105 millimetre
Product weight	2.81 kilogram
Compliances	RoHS conform
Product Tradename	NZM
Product Type	Molded case circuit breaker
Product Sub Type	Thermo-magnetic
Delivery program	
Number of poles	Three-pole
Amperage Rating	250 A
Features	Motor drive optional Protection unit
Special features	Rated current = rated uninterrupted current: 250 A
Technical Data - Electrical	
Voltage rating	690 V - 690 V
Instantaneous current setting (Ii) - min	1500 A
Instantaneous current setting (Ii) - max	2500 A
Overload current setting (Ir) - min	200 A
Overload current setting (Ir) - max	250 A
Short delay current setting (Isd) - min	0 A
Short delay current setting (Isd) - max	0 A
Short-circuit release non-delayed setting - min	6 A
Short-circuit release non-delayed setting - max	10 A
Rated short-circuit breaking capacity Ics (IEC/EN 60947) at 400/415 V, 50/60 Hz	70 kA
Electrical connection type of main circuit	Screw connection
Handle type	Rocker lever
Technical Data - Mechanical	
Mounting Method	Built-in device plug-in technique
Degree of protection	IP20
Number of auxiliary contacts (change-over contacts)	0
Number of auxiliary contacts (normally closed contacts)	0
Number of auxiliary contacts (normally open contacts)	0
Position of connection for main current circuit	Back side
Special features	Rated current = rated uninterrupted current: 250 A
Design verification as per IEC/EN 61439 - technical data	
Equipment heat dissipation, current-dependent	58.13 W
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	70 °C
Ambient storage temperature - min	40 °C
Ambient storage temperature - max	70 °C
Design verification as per IEC/EN 61439	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.

10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
· ·	
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.