

Label; emergency switching off; yellow; H x W = 50 x 33 mm; with IEC60417-5638 symbol



Part no. **M22-XZK-ESS**
180470

General specifications		
Product name		Eaton Moeller® series M22 Accessory Emergency-Stop label
Part no.		M22-XZK-ESS
EAN		4015081756353
Product Length/Depth		50 millimetre
Product height		1 millimetre
Product width		33 millimetre
Product weight		0.002 kilogram
Certifications		DNV GL LR
Product Tradename		M22
Product Type		Accessory
Product Sub Type		Emergency-Stop label
Features & Functions		
Color		Yellow
Inscription		EMERGENCY STOP
Language		Other
RAL-number		1004
Shape		Rectangular
General information		
Degree of protection		IP66
Size		33 x 50 mm
Communication		
Connection to SmartWire-DT		No
Design verification		
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of assemblies		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		Not applicable.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Text plate for command devices (EC000624)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Identification plate for command devices (ecl@ss13-27-37-12-25 [AKF043019])

Literal imprint			Emergency Stop
Language of the imprint			Other
Imprint ISO symbols			Symbol "Emergency Stop"
Colour			Yellow
Shape			Rectangular
Width		mm	33
Height		mm	1
Outer diameter		mm	0