DATASHEET - NZMS1-4-A20

Circuit-breaker 4 pole, 20A

Part no.	NZMS1-4-A20
Catalog No.	109948

EATON[®] Powering Business Worldwide[®]

Similar to illustration

Delivery program			
Switching capacity			
400/415 V 50 Hz	I _{cu}	kA	70
Rated current = rated uninterrupted current			
Rated current = rated uninterrupted current	$I_n = I_u$	А	20
Neutral conductor	% of phase conductor	%	100
Setting range			
Overload trip			
сф.	۱ _r	A	16 - 20
Main pole	I _r	A	15 - 20
Short-circuit releases			
Non-delayed	$I_i = I_n x \dots$		350 A fixed

Technical data

Ambient temperature Image: Constraint of the second of	
Operation °C -25 - +70 Circuit-breakers In = Iu A 20 Switching capacity In = Iu A 20 Rated short-circuit breaking capacity Icn Icn Icn	
Circuit-breakers Rated current = rated uninterrupted current In = Iu A 20 Switching capacity Rated short-circuit breaking capacity Icn Icn I	
Rated current = rated uninterrupted current In = Iu A 20 Switching capacity Rated short-circuit breaking capacity Icn Icn	
Switching capacity Rated short-circuit breaking capacity I _{cn}	
Rated short-circuit breaking capacity I _{cn} I _{cn}	
Icu to JEC/EN 609/7 test such 0.1.00	
400/415 V 50/60 Hz I _{cu} kA 70	
Terminal capacity	
Round copper conductor	
Box terminal	
Solid mm ² 1 x (6 - 16) 2 x (4 - 16)	
Stranded mm ² 1 x (6 - 70) ³⁾ 2 x (4 - 25)	
Bolt terminal and rear-side connection	
Direct on the switch	
Solid mm ² 1 x (6 - 16) 2 x (4 - 16)	
Stranded mm ² 1 x (6 - 70) ³⁾ 2 x (4 - 25)	

Design verification as per IEC/EN 61439

Technical data for design verification

Equipment heat dissipation, current-dependent	P _{vid}	W	9.82
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

protection (ecl@3310.0.1-21-01-04-03 [A02110010])		
Rated permanent current lu	А	20
Rated voltage	V	690 - 690
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	70
Overload release current setting	А	16 - 20
Adjustment range short-term delayed short-circuit release	Α	0 - 0
Adjustment range undelayed short-circuit release	А	350 - 350
Integrated earth fault protection		No
Type of electrical connection of main circuit		Frame clamp
Device construction		Built-in device fixed built-in technique
Suitable for DIN rail (top hat rail) mounting		No
DIN rail (top hat rail) mounting optional		Yes
Number of auxiliary contacts as normally closed contact		0
Number of auxiliary contacts as normally open contact		0
Number of auxiliary contacts as change-over contact		0
With switched-off indicator		No
With under voltage release		No
Number of poles		4
Position of connection for main current circuit		Front side
Type of control element		Rocker lever
Complete device with protection unit		Yes
Motor drive integrated		No

Degree of protection (IP) IP20	Motor drive optional	No	
	Degree of protection (IP)	IP20	

Additional product information (links)

additional technical information for NZM power switch

https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf