Circuit-breaker 3-pole 63A, system/cable protection, withdrawable unit



Part no. NZMS2-A63-SVE Catalog No. 113285

Similar to illustration

| Delivery program | | | |
|---|---------------------|----|---------|
| Switching capacity | | | |
| 400/415 V 50 Hz | I _{cu} | kA | 70 |
| Rated current = rated uninterrupted current | | | |
| Rated current = rated uninterrupted current | $I_n = I_u$ | Α | 63 |
| Setting range | | | |
| Overload trip | | | |
| 中 | I _r | А | 50 - 63 |
| Short-circuit releases | | | |
| Non-delayed | $I_i = I_n x \dots$ | | 6 - 10 |

Technical data

General

| Ambient temperature | | | |
|--|-----------------|----|-------------|
| Ambient temperature, storage | | °C | - 40 - + 70 |
| Operation | | °C | -25 - +70 |
| Circuit-breakers | | | |
| Rated current = rated uninterrupted current | $I_n = I_u$ | Α | 63 |
| Switching capacity | | | |
| Rated short-circuit breaking capacity I_{cn} | I _{cn} | | |
| Icu to IEC/EN 60947 test cycle 0-t-C0 | Icu | kA | |
| 400/415 V 50/60 Hz | I _{cu} | kA | 70 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|------------------|----|--|
| Equipment heat dissipation, current-dependent | P _{vid} | W | 20.24 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 70 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |

| 10.5 Protection against electric shock | Does not apply, since the entire switchgear needs to be evaluated. |
|--|--|
| 10.6 Incorporation of switching devices and components | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

| ated permanent current lu A ated voltage V ated short-circuit breaking capacity lcu at 400 V, 50 Hz kA verload release current setting A djustment range short-term delayed short-circuit release A | 63 690 - 690 70 |
|---|-----------------------------------|
| ated short-circuit breaking capacity Icu at 400 V, 50 Hz kA verload release current setting A | 70 |
| verload release current setting A | |
| v | 50. 60 |
| djustment range short-term delayed short-circuit release A | 50 - 63 |
| , | 0 - 0 |
| djustment range undelayed short-circuit release A | 378 - 630 |
| ategrated earth fault protection | No |
| /pe of electrical connection of main circuit | Screw connection |
| evice construction | Built-in device plug-in technique |
| uitable for DIN rail (top hat rail) mounting | No |
| IN rail (top hat rail) mounting optional | No |
| umber of auxiliary contacts as normally closed contact | 0 |
| umber of auxiliary contacts as normally open contact | 0 |
| umber of auxiliary contacts as change-over contact | 0 |
| /ith switched-off indicator | No |
| /ith under voltage release | No |
| umber of poles | 3 |
| osition of connection for main current circuit | Back side |
| /pe of control element | Rocker lever |
| omplete device with protection unit | Yes |
| lotor drive integrated | No |
| lotor drive optional | Yes |
| egree of protection (IP) | IP20 |

Additional product information (links)

additional technical information for NZM power switch https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf