DATASHEET - NZMN3-4-A320-SVE



Circuit-breaker, 4p, 320A, plug-in module

Part no. NZMN3-4-A320-SVE Catalog No. 168508

NZMN3-4-A320-SVE

Alternate Catalog

No.

EL-Nummer 0004357593

(Norway)



Delivery program Switching capacity 400/415 V 50 Hz kA 50 Rated current = rated uninterrupted current Rated current = rated uninterrupted current $I_n = I_u$ Α 320 Neutral conductor % of phase % 100 conductor **Setting range** Overload trip 250 - 320 Main pole Α Short-circuit releases 1> Non-delayed 6 - 10 $I_i = I_n \times \dots$

Technical data

G	en	ei	al
u	GII	CI	aı

Ambient temperature					
Ambient temperature, storage		°C	- 40 - + 70		
Operation		°C	-25 - +70		
Circuit-breakers					
Rated current = rated uninterrupted current	$I_n = I_u$	Α	320		
Use in unearthed supply systems		V	≦ 690		
Switching capacity					
Rated short-circuit making capacity	I _{cm}				
240 V	I _{cm}	kA	330		
Rated short-circuit breaking capacity I_{cn}	I _{cn}				
Icu to IEC/EN 60947 test cycle O-t-CO	lcu	kA			
400/415 V 50/60 Hz	I _{cu}	kA	50		
500 V DC	I _{cu}	kA	30		
750 V DC	I _{cu}	kA	30		
Ics to IEC/EN 60947 test cycle 0-t-C0-t-C0	Ics	kA			
500 V DC	I _{cs}	kA	30		
750 V DC	I _{cs}	kA	30		
Terminal canacity					

Τ	ermi	inal	ca	pac	itv
	•			P	,

Accessories required			NZM3-XSVS
Optional accessories			Box terminal Tunnel terminal connection on rear
Cu strip (number of segments x width x segment thickness)			
Bolt terminal and rear-side connection			
Flat copper strip, with holes	min.	mm	6 x 16 x 0.8
Flat copper strip, with holes	max.	mm	10 x 32 x 1.0 + 5 x 32 x 1.0

Connection width extension		mm	(2 x) 10 x 50 x 1.0
Copper busbar (width x thickness)	mm		
Bolt terminal and rear-side connection			
Direct on the switch			
	max.	mm	30 x 10 + 30 x 5

Design verification as per IEC/EN 61439

Technical data for design verification			
Equipment heat dissipation, current-dependent	P _{vid}	W	94
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

 $Low-voltage\ industrial\ components\ (EG000017)/\ Power\ circuit-breaker\ for\ trafo/generator/installation\ protection\ (EC000228)$

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

protection (ect@ss10.0.1-27-37-04-09 [AJZ710013])		
Rated permanent current lu	А	320
Rated voltage	V	690 - 690
Rated short-circuit breaking capacity Icu at 400 V, 50 Hz	kA	50
Overload release current setting	Α	250 - 320
Adjustment range short-term delayed short-circuit release	Α	0 - 0
Adjustment range undelayed short-circuit release	Α	6 - 10
Integrated earth fault protection		No
Type of electrical connection of main circuit		Screw connection
Device construction		Built-in device plug-in technique
Suitable for DIN rail (top hat rail) mounting		No
DIN rail (top hat rail) mounting optional		No
Number of auxiliary contacts as normally closed contact		0

Number of auxiliary contacts as normally open contact	0
Number of auxiliary contacts as change-over contact	0
With switched-off indicator	No
With under voltage release	No
Number of poles	4
Position of connection for main current circuit	Front side
Type of control element	Rocker lever
Complete device with protection unit	Yes
Motor drive integrated	No
Motor drive optional	Yes
Degree of protection (IP)	IP20

Additional product information (links)

additional technical information for NZM power switch

https://es-assets.eaton.com/DOCUMENTATION/PDF/nzm_technic_de_en.pdf