## DATASHEET - NZMN3-4-A500/320-SVE



Circuit-breaker, 4p, 500A, 320A in 4th pole, withdrawable unit

Powering Business Worldwide

Part no. NZMN3-4-A500/320-SVE 168513

Catalog No. NZMN3-4-A500R-SVE

Alternate Catalog

**EL-Nummer** (Norway)

0004357598

Similar to illustration

# **Delivery program**

Don't or y program			
Switching capacity			
400/415 V 50 Hz	I <sub>cu</sub>	kA	50
Rated current = rated uninterrupted current			
Rated current = rated uninterrupted current	$I_n = I_u$	Α	500
Neutral conductor	% of phase conductor	CSA	60
Setting range			
Overload trip			
Main pole	I <sub>r</sub>	Α	250 - 320
Short-circuit releases			
Non-delayed	$I_i = I_n \times \dots$		6 - 10

## **Technical data**

#### General

Ambient temperature					
Ambient temperature, storage		°C	- 40 - + 70		
Operation		°C	-25 - +70		
Circuit-breakers Circuit-breakers					
Rated current = rated uninterrupted current	$I_n = I_u$	Α	500		
Switching capacity					
Rated short-circuit breaking capacity I <sub>cn</sub>	I <sub>cn</sub>				
Icu to IEC/EN 60947 test cycle 0-t-C0	lcu	kA			
400/415 V 50/60 Hz	I <sub>cu</sub>	kA	50		
500 V DC	I <sub>cu</sub>	kA	30		
750 V DC	I <sub>cu</sub>	kA	30		
Ics to IEC/EN 60947 test cycle 0-t-C0-t-C0	Ics	kA			
500 V DC	Ics	kA	30		
750 V DC	I <sub>cs</sub>	kA	30		

### Design verification as per IEC/EN 61439

2001gii 1011ii uu 101 120, 211 01 100			
Technical data for design verification			
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	130.5
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.

10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation protection (EC000228)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss10.0.1-27-37-04-09 [AJZ716013])

Number of auxiliary contacts as normally open contact		0
Number of auxiliary contacts as change-over contact		0
•		
•		
•		0
Number of auxiliary contacts as change-over contact		0
•		0
•		
•		
With switched-off indicator		No
With under voltage release		No
With under voltage release		No
•		
Number of poles		4
Position of connection for main current circuit		Front side
Type of control element		Rocker lever
Complete device with protection unit		Yes
·		
Motor drive integrated		No
Motor drive optional		Yes
Degree of protection (IP)		IP20

### **Additional product information (links)**

additional technical information for NZM power switch

ftp://ftp.moeller.net/DOCUMENTATION/PDF/nzm\_technic\_de\_en.pdf