## DATASHEET - NZM2/3-XA60AC/DC-PI



Shunt release for NZM2/3, 60AC/DC, Push-in terminals

Part no. NZM2/3-XA60AC/DC-PI Catalog No. 189801



Similar to illustration

**Delivery program** 

| benvery program       |         |   |   |  |
|-----------------------|---------|---|---|--|
| Product range         |         |   | Accessories   |  |
| Accessories           |         |   | Shunt release   |  |
| Accessories           |         |   | Shunt releases  |  |
| Standard/Approval     |         |   | UL/CSA, IEC   |  |
| Construction size     |         |   | NZM2/3  |  |
| Description           |         |   | When the shunt release is live, contact with the circuit-breaker's main contacts on switching on is reliably prevented.  Shunt release modules cannot be installed simultaneously with early-make contact NZMXHIV, untervoltage release NZMXU, or relais modules NZMX2A |  |
| Connection type       |         |   | with push in terminal   |  |
| Auxiliary contacts    |         |   | without auxiliary contact   |  |
| Rated control voltage | $U_{s}$ | V | 60 V AC/DC  |  |
| For use with          |         |   | NZM2(-4), N(S)2(-4)<br>NZM3(-4), N(S)3(-4)  |  |

## **Design verification as per IEC/EN 61439**

| Design verification as per IEC/EN 61439   |  |
|---|--|
| IEC/EN 61439 design verification  |  |
| 10.2 Strength of materials and parts  |  |
| 10.2.2 Corrosion resistance   | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  | Meets the product standard's requirements.   |
| 10.2.5 Lifting  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |  |
| 10.9.2 Power-frequency electric strength  | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility   | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## Technical data ETIM 6.0

| Low-voltage industrial components (EG000017) / Shunt release (for power circuit breaker) (EC001023)  |  |   |                         |  |
|--|--|---|-------------------------|--|
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Full load current trip (ecl@ss8.1-27-37-04-18 [AKF016010]) |  |   |                         |  |
| Rated control supply voltage Us at AC 50HZ   |  | ٧ | 60 - 60                 |  |
| Rated control supply voltage Us at AC 60HZ   |  | ٧ | 60 - 60                 |  |
| Rated control supply voltage Us at DC  |  | ٧ | 60 - 60                 |  |
| Voltage type for actuating   |  |   | AC/DC                   |  |
| Initial value of the undelayed short-circuit release - setting range   |  | Α | 0                       |  |
| End value adjustment range undelayed short-circuit release   |  | Α | 0                       |  |
| Type of electric connection  |  |   | Spring clamp connection |  |
| Number of contacts as normally open contact  |  |   | 0                       |  |
| Number of contacts as normally closed contact  |  |   | 0                       |  |
| Number of contacts as change-over contact  |  |   | 0                       |  |
| Suitable for power circuit breaker   |  |   | Yes                     |  |
| Suitable for off-load switch   |  |   | Yes                     |  |
| Suitable for motor safety switch   |  |   | Yes                     |  |
| Suitable for overload relay  |  |   | No                      |  |

## **Approvals**

| Product Standards           | UL489; CSA-C22.2 No. 5-09; IEC60947, CE marking |
|-----------------------------|---|
| UL File No.                 | E140305   |
| UL Category Control No.     | DIHS  |
| CSA File No.                | 22086   |
| CSA Class No.               | 1437-01   |
| North America Certification | UL listed, CSA certified                        |