# **DATASHEET - NZM3-XBSM**



## Interface module for NZM3 PXR20, connection for communication

Powering Business Worldwide\*

Part no. NZM3-XBSM Catalog No. 189826

EL-Nummer (Norway) 4362676

Similar to illustration

**Delivery program** 

Delivery program	
Product range	Accessories
Accessories	Interface module
Standard/Approval	UL/CSA, IEC
Construction size	NZM3
Description	For universal connection of optional circuit breaker functions. Required for communication The connection types depend on the design of the interface module. Circuit breaker status detection (I, +, 0) for the electronic trip unit. The switch's status can be communicated. 24 V DC auxiliary power connection. Connection for Communications Adapter Module (CAM). Optional CAM available for various Fieldbus communication systems (Profibus DP, SmartWire-DT, Ethernet-based Fieldbus). Connection to optional, internal Modbus RTU module. Mechanical pass-through of the switch's status (I, 0) for use by the remote operator.
Connection type	with push in terminal With bolt connection
For use with	NZM3(-4)-VX(MX)(PX)(PMX)

### **Technical data**

#### **Supply connection**

Supply connection			
Rated control voltage	$U_s$	V	
DC	Us	V DC	24 - 24
Tolerance			+/- 20%
max. current consumption			100
Connection			
Connection type			Screw terminal
Stripping length		mm	5
Terminal capacity			
Solid		$\text{mm}^2$	1 x (0.2 - 1.5)
Stranded		mm <sup>2</sup>	1 x (0.2 - 1.5)
		AWG	1 x AWG 24 - AWG 16
with uninsulated end sleeve in accordance with DIN46228 / 1		mm <sup>2</sup>	1 x (0,25 - 0,75)
with insulated end sleeve in accordance with DIN46224 / 4		mm <sup>2</sup>	1 x (0,25 - 0,75)
Min. tightening torque		Nm	0.22
Maximum tightening torque		Nm	0.25
CAM connection			
Connection technique			5-pin plug connector
Connection type			assembled CAM cable

Connection type	assembled CAM cable
Internal COM connection	
Connection technique	10-pin plug connector
Connection type	pre-wired cable to the Modbus module

# **Design verification as per IEC/EN 61439**

IEC/EN 61439 design verification	
10.2 Strength of materials and parts	
10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.

10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions	Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Accessories for low-voltage switch technology (EC002498)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Component for low-voltage switch technology (accessories) (ecl@ss10.0.1-27-37-13-92 [AKN570013])

Type of accessory Communication and measuring function

# **Approvals**

Product Standards	In preparation
Degree of Protection	Installation in the switch